

	<b>Additional information and clarifications</b>	<b>Form designation</b>	<b>QF-G-029</b>
		<b>Page no.</b>	<b>1/1</b>

PUBLIC ENTERPRISE ELECTRIC POWER INDUSTRY OF SERBIA, BELGRADE  
PE EPS HQ  
2 Carice Milice  
Number: 12.01. 15011/ 18 -1 E  
Belgrade, 26 -02- 2016

In accordance with Article 54 and 63 of Public Procurement Law ("Official Gazette of the Republic of Serbia" number 124/12, 14/15 and 68/15), the Committee for public procurement number 1000/0156/2015, for the procurement of services "Information system to support generation and sale of electricity (Phase 2) and modernization of control and information SCADA system", upon the request of interested party, issues the following

**ADDITIONAL INFORMATION OR CLARIFICATIONS REGARDING TENDER PREPARATION  
No. 8**

Five or more days prior to expiry date foreseen for the submission of tenders, the interested party asked the Employer, in an written request, for the additional information, i.e. clarifications and the Employer, within three days from the date of the receipt of the request, shall publish the following information i.e. clarifications **on the Public Procurement Portal and website of the Employer:**

**QUESTION 1:** „With respect to your document Additional information or clarification regarding tender preparation No. 6, with regards to the question and your answer on I.b)

Q: for 1 generating unit  
Number (roughly estimated) of binary inputs, measured value inputs, measured value output?

A: For Thermal PP: >2000 BI, >700 BO, >500 AI, <100 AO For Hydro  
PP: >400 BI, >150 BO, >90 AI, <32 AO

Does the given number of BI, BO, AI and AO refer to the entire generation portfolio of EPS or is this number for 1 thermal PP/hydro PP only? We would appreciate receiving clarification.“

ANSWER 1:

Yes, it refers to one thermal or hydro power plant and not to the entire PE EPS.

← THE COMMITTEE FOR PP/1000/0156/2015

