



**Napomena:**

Crtež je informativnog karaktera. Isporučilac oslonca dostavlja detaljnu dokumentaciju u skladu sa rezultatima proračuna.  
AKZ zaštita u klasi kao za cevovode.

Nepokretni oslonac NO-A						
$F_x$ , kN	$F_y$ , kN	+ $F_z$ , kN	- $F_z$ , kN	$M_x$ , kNm	$M_y$ , kNm	$M_z$ , kNm
20	100	17	100	50	2	50

 KFG INDUSTRIAL GROUP		Ime M. Ostojčić		Potpis S. Genić		Datum 09. 2012			
CUSTOMER/NARUČILAC: ELECTRIC POWER INDUSTRY OF SERBIA									
DRAW/ CRTAO CHECKED/ KONTROLISAO	DATE/DATUM	NAME/IME	SCALE/ RAZMERA 1:5	 <small>GLYDE BERGMANN          LAKESIDE INDUSTRIAL          LAKESIDE          DOUGLASSVILLE, GA 30135          Tel : +1 770 526 0200          Fax : +1 770 526 2800          www.dnb.co.uk</small>				<small>No reproduction or publication of this drawing may be made and no article may be manufactured or assembled in accordance with this drawing without prior written consent. Protected by U.S. Design Right under the terms of the copyright, design and patents act 1988.</small>	
DESCRIPTION/NAZIV: REPLACEMENT OF ASH SLURRY SYSTEM KOSTOLAC A ZAMENA SISTEMA ODPEPELJIVANJA KOSTOLAC A FIXED RESTRAINT (ANCHOR) NO-A NEPOKRETNI OSLOMAC NO-A				DRAWING INTERNAL No./BROJ INTERNOG CRTEZA: U 055 06M 235 DRAWING No./BROJ CRTEZA: C062923635					
SHEET/LIST: 1 OD 1				REV: 00					
CAD: ACAD 2012									