



JAVNO PREDUZEĆE ELEKTROPRIVREDA SRBIJE, BEOGRAD

Carice Milice 2

Number: 1833/59-14

Belgrade,

01-08-2014

Subject: additional clarifications no. 4 in accordance with Article 63 paragraph 3 of Public Procurement Law ("Official Gazette of the Republic of Serbia" number 124/12) in a negotiation procedure without publishing the invitation to tender by the several Employers for the public procurement of the services: Pumping out the silted water and silt in the Open Pit Mine MB Kolubara – Tamnava - West Field, CPP number 08/14/DUKN, for which notification on initiation of negotiation procedure without publishing the invitation to tender was published on Public Procurement Portal on 23.07.2014.

Five and more days prior to expiry date foreseen for submission of tenders in subject public procurement procedure, interested parties have submitted to the Employer via e-mail request for additional information, i.e. clarifications, regarding which the Employer, i.e. Public Procurement Committee, in accordance with provision of Article 54 paragraph 12 item 1) of the Law shall provide the following information i.e. clarifications within three days from the day of the receipt of the request:

Question 1: In item 2.3 of Tender Documents the following is stated: "If for the performance of subject procurement the Bidder offers performance using electric motor pumps, the Employer 2 shall provide electricity connection, with the capacity of 24 to 30 MW, 6000V voltage, 50Hz on plateau". Please answer whether it means that electricity connection also refers to provision of appropriate switchyards for connection of individual consumers (temporary TS) by the Employer or is it necessary for the Bidder to include in its bid the delivery and installation of required switchyards for individual connection of consumers.

Answer 1: You will have end tower of transmission line without connection equipment. It is your obligation to connect with the transmission line in accordance with the needs of your devices!



PUBLIC PROCUREMENT COMMITTEE CPP 08/14/DUKN

Страна 1 од 1