


Napomena:

- Crtež je informativnog karaktera. Isporučilac oslonca dostavlja detaljnu dokumentaciju u skladu sa rezultatima proračuna
- AKZ ZAŠTITA U KLASI KAO ZA CEVOVODE.

Planarni oslonac PL						
F_x , kN	F_y , kN	+ F_z , kN	- F_z , kN	M_x , kNm	M_y , kNm	M_z , kNm
5	0	3	20	0	0	0



 PROJEKTOVANJE IZVRŠIO KFG INDUSTRIAL GROUP		Datum 09. 2012	
Odgovorni projektant: M.Ostojić		Potpis	
Projektant: S.Genić			
CUSTOMER/NARUČILAC: ELECTRIC POWER INDUSTRY OF SERBIA			
DRAW/ CRTAO	DATE/DATUM	NAME/IME	SCALE/ RAZMERA 1: 4
CHECKED/ KONTROLISAO			
DESCRIPTION/NAZIV: REPLACEMENT OF ASH SLURRY SYSTEM KOSTOLAC A ZAMENA SISTEMA ODPELJIVANJA KOSTOLAC A PLANAR RESTRAINT PL PLANARNI OSLONAC PL		DRAWING INTERNAL No./BROJ INTERNOG CRTEŽA: U 055 06M 239 DRAWING No./BROJ CRTEŽA: C062923639	
		SHEET/LIST: 1 OD 1	REV: 00
		CAD: ACAD 2012	



CLYDE BERGMANN
 LANCASHIRE ROYALTY
 LANCASHIRE
 SOULSBURY, SOUTH YORKSHIRE
 DN4 9PL, ENGLAND
 Tel: +44 (0)1522 300200
 Fax: +44 (0)1522 300220
 www.cbm.co.uk

No reproduction or publication of this drawing may be made and no article may be manufactured or assembled in accordance with this drawing without prior written consent. Protected by UK Design Right under the terms of the copyright, design and patents act 1988.