









Detalj "A"
Razmera 1:2



Napomena:
- Crtež je informativnog karaktera. Isporučilac oslonca dostavlja detaljnu dokumentaciju u skladu sa rezultatima proračuna

- AKZ ZAŠTITA U KLASI KAO ZA CEVOVODE.

Vodeći oslonac VO-A						
Fx, kN	*Fy*, kN	*+Fz*, kN	*-Fz*, kN	*Mx*, kNm	*My*, kNm	*Mz*, kNm
16	-	9	99	-	-	-



3032

PROJEKTOVANJE IZVRŠIO
KFG INDUSTRIAL GROUP

		Potpis	Datum
Odgovorni projektant:	M.Ostojić		09. 2012
Projektant:	S.Genić		

CUSTOMER/NARUČILAC: ELECTRIC POWER INDUSTRY OF SERBIA

	DATE/DATUM	NAME/IME	SCALE/ RAZMERA
DRAW/ CRTAO			1:5
CHECKED/ KONTROLISAO			

CLYDE BERGEMANN
LAKESIDE BOULEVARD
LAKESIDE
DONCASTER, SOUTH YORKSHIRE
DN4 5PL, ENGLAND
Tel : +44 (0)1302 552200
Fax : +44 (0)1302 369055
www.clyde.co.uk

No reproduction or publication of this drawing may be made and no article may be manufactured or assembled in accordance with this drawing without prior written consent. Protected by U.K. Design Right under the terms of the copyright, design and patents act 1988.

DESCRIPTION/NAZIV:
REPLACEMENT OF ASH SLURRY SYSTEM KOSTOLAC A
ZAMENA SISTEMA ODPEPELJIVANJA KOSTOLAC A
GUIDE VO-A

VODEĆI OSLONAC VO-A

DRAWING INTERNAL No./BROJ INTERNOG CRTEŽA:
U 055 06M 237
DRAWING No./BROJ CRTEŽA:
C062923637

SHEET/LIST: 1 OD 1
REV: 00
CAD: ACAD 2012